

Soluble Sulfate Test Certificate

Client: Cullimore's Mix Ltd
 Netherhills
 Whitminster
 Gloucestershire GL2 7PD

Source of Material: Ashton Keynes

Test Method: BS EN 1744-1 : 2009 + A1: Clause 12

Sample Ref	Sample Description	Date Received	Date Test Started	Acid Soluble Sulfate Content as SO ₃
16/067	4/20	26.01.16	17.02.16	<0.1%
16/074	0/4 sand	26.01.16	17.02.16	<0.1%

Signed:



Date of Issue: 23rd February 2016

on behalf of Testing & Consultancy Services Limited